

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.42				Y
2	8.20				Y
3	8.31				Y
4	8.26				Y
5	8.28				Y
6	8.36				Y
7	8.45				Y
8	8.43				Y
9	8.46				Y
10	8.11				Y
11	8.37				Y
12	8.40				Y
13	8.32				Y
14	8.27				Y
15	8.38				Y
16	8.27				Y
17	8.36				Y
18	8.34				Y
19	8.38				Y
20	8.61				Y
21	8.63				Y
22	8.58				Y
23	7.87				Y
24	7.89				Y
25	7.79				Y
26	7.80				Y
27	7.78				Y
28	7.73				Y
29					Y
30					Y
31					Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: February 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Dan Waterbury

Signature:

Date: 3/08/2022

Send to DWP within 10 days after end of sampling period