

Day	pH	Alk	Phos	Other	Y/N
1	7.73				Y
2	7.65				Y
3	7.77				Y
4	7.84				Y
5	7.96				Y
6	7.99				Y
7	7.92				Y
8	7.81				Y
9	7.86				Y
10	7.94				Y
11	8.01				Y
12	7.99				Y
13	8.05				Y
14	7.90				Y
15	8.03				Y
16	7.90				Y
17	7.96				Y
18	7.99				Y
19	7.98				Y
20	7.99				Y
21	7.93				Y
22	7.90				Y
23	7.97				Y
24	8.05				Y
25	8.48				Y
26	8.48				Y
27	8.16				Y
28	8.20				Y
29	8.20				Y
30	8.09				Y
31	8.21				Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: March 2022  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 4/08/2022

Send to DWP within 10 days after end of sampling period