

Day	pH	Alk	Phos	Other	Y/N
1	8.20				Y
2	8.24				Y
3	8.20				Y
4	8.23				Y
5	8.20				Y
6	8.23				Y
7	8.06				Y
8	8.02				Y
9	8.04				Y
10	8.06				Y
11	8.36				Y
12	8.34				Y
13	8.15				Y
14	8.17				Y
15	8.12	45.0			Y
16	8.05				Y
17	8.23				Y
18	8.23				Y
19	8.13				Y
20	8.16				Y
21	8.15				Y
22	8.16				Y
23	8.20				Y
24	8.18				Y
25	8.02				Y
26	8.01				Y
27	8.01				Y
28	8.01				Y
29	7.91				Y
30	7.94	45.0			Y
31					Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: April 2022  
*Month/Year*

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )



*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Dan Waterbury

Signature:

Date: 5/10/2022

Send to DWP within 10 days after end of sampling period