

Day	pH	Alk	Phos	Other	Y/N
1	7.99				
2	7.94				
3	7.92				
4	7.94				
5	7.99				
6	7.91				
7	7.96				
8	7.93				
9	7.95				
10	7.96				
11	8.00				
12	8.07	45.0			
13	8.12				
14	8.09				
15	8.30				
16	8.16				
17	8.21				
18	8.14				
19	8.26				
20	8.31				
21	7.95				
22	7.94				
23	7.97				
24	8.16				
25	8.18				
26	8.24	45.0			
27	8.18				
28	8.22				
29	8.28				
30	8.23				
31					

(No = N = Excursion) Total N's

0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: June 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 7/8/2022

Send to DWP within 10 days after end of sampling period