

Day	pH	Alk	Phos	Other	Y/N
1	8.31				
2	8.13				
3	8.29				
4	8.22				
5	8.31				
6	8.37				
7	8.38				
8	8.28	45.0			
9	8.35				
10	8.31				
11	8.32				
12	8.21				
13	8.29				
14	8.28				
15	8.26				
16	8.09				
17	8.34				
18	8.22				
19	8.13				
20	8.30	45.0			
21	8.29				
22	8.31				
23	8.27				
24	8.08				
25	8.18				
26	8.15				
27	8.22				
28	8.12				
29	7.92				
30	8.16				
31	8.21				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: July 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 8/8/2022

Send to DWP within 10 days after end of sampling period