

Day	pH	Alk	Phos	Other	Y/N
1	15.4				Y
2	15.3				Y
3	15.2				Y
4	14.9				Y
5	14.7				Y
6	14.9				Y
7	14.5				Y
8	14.1	40.0			Y
9	14.4				Y
10	14.2				Y
11	14.7				Y
12	14.8				Y
13	14.6				Y
14	14.5				Y
15	14.3				Y
16	14.2				Y
17	14.0				Y
18	14.3				Y
19	13.7				Y
20	13.8				Y
21	13.6				Y
22	13.7	45.0			Y
23	13.8				Y
24	13.8				Y
25	13.3				Y
26	13.9				Y
27	13.8				Y
28	13.5				Y
29	13.8				Y
30	13.5				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: September 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 10/10/2022

Send to DWP within 10 days after end of sampling period