

Day	pH	Alk	Phos	Other	Y/N
1	8.15	40.0			
2	8.12				
3	8.17				
4	8.09				
5	7.92				
6	7.97				
7	7.98				
8	7.96				
9	8.02				
10	7.82				
11	7.91				
12	7.96				
13	8.14	40.0			
14	8.35				
15	8.17				
16	8.36				
17	8.43				
18	8.45				
19	8.32				
20	8.35				
21	8.44				
22	8.46				
23	8.48				
24	8.50				
25	8.42	40.0			
26	8.60				
27	8.58				
28	8.30				
29	8.12				
30	8.10				
31	8.00				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: October 2022  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 11/8/2022

Send to DWP within 10 days after end of sampling period