

Day	pH	Alk	Phos	Other	Y/N
1	8.01				
2	8.12				
3	8.14				
4	8.18				
5	7.88				
6	8.01				
7	7.81	40.0			
8	7.75				
9	7.70				
10	8.13				
11	8.09				
12	8.13				
13	8.12				
14	8.21				
15	8.36				
16	8.24				
17	8.39				
18	8.29				
19	8.31	40.0			
20	8.36				
21	8.06				
22	8.06				
23	7.88				
24	7.83				
25	7.96				
26	7.86				
27	7.75				
28	7.94				
29	7.92				
30	7.86				
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: November 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 12/8/2022

Send to DWP within 10 days after end of sampling period