

Day	pH	Alk	Phos	Other	Y/N
1	7.76				
2	7.91				
3	7.99				
4	8.01				
5	8.11				
6	7.82	40.0			
7	7.93				
8	7.99				
9	7.99				
10	8.01				
11	8.05				
12	8.01				
13	8.07				
14	7.99				
15	7.93				
16	7.87				
17	8.01				
18	7.98	40.0			
19	7.88				
20	7.83				
21	7.87				
22	7.77				
23	7.98				
24	7.89				
25	7.83				
26	7.81				
27	7.81				
28	7.72				
29	7.71				
30	7.59	40.0			
31	7.79				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: October 2022

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 1/7/2023

Send to DWP within 10 days after end of sampling period