

Day	pH	Alk	Phos	Other	Y/N
1	7.58				
2	7.67				
3	7.64				
4	7.52				
5	7.46				
6	7.43	40.0			
7	7.48				
8	7.70				
9	7.81				
10	8.12				
11	8.26				
12	8.16				
13	8.27				
14	8.31				
15	8.29				
16	8.16				
17	8.08				
18	8.17	40.0			
19	8.19				
20	8.24				
21	8.26				
22	8.46				
23	8.15				
24	8.06				
25	7.85				
26	7.80				
27	7.69				
28	7.72				
29	7.83				
30	7.64	40.0			
31	7.67				

<<Have

minimums  
 been met for  
 this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: January 2023  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

  
 Alk 

30.0
------


 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Other 

--

 (\_\_\_\_\_)

Print Name: Dan Waterbury  
 Signature:   
 Date: 2/7/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 

0
---