

Day	pH	Alk	Phos	Other	Y/N
1	7.68				Y
2	7.71				Y
3	7.75				Y
4	7.79				Y
5	7.74				Y
6	7.80				Y
7	7.85				Y
8	7.84				Y
9	7.85				Y
10	7.86				Y
11	7.91	40.0			Y
12	7.92				Y
13	7.93				Y
14	7.95				Y
15	7.96				Y
16	7.91				Y
17	7.91				Y
18	8.03				Y
19	7.82				Y
20	7.94				Y
21	7.91				Y
22	7.96				Y
23	8.01	40.0			Y
24	8.27				Y
25	8.31				Y
26	8.26				Y
27	7.82				Y
28	7.86				Y
29					
30					
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Wickiup Water District

Entry Point: B

Sample Period: February 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Dan Waterbury

Signature: 

Date: 3/07/2023

Send to DWP within 10 days after end of sampling period