

Day	pH	Alk	Phos	Other	Y/N
1	8.16				
2	8.14				
3	8.14				
4	8.12				
5	7.92				
6	8.13				
7	8.11				
8	7.74				
9	7.91				
10	7.85				
11	7.84	40.0			
12	7.98				
13	8.00				
14	7.98				
15	7.92				
16	7.75				
17	7.73				
18	7.73				
19	7.77				
20	7.81				
21	7.75				
22	7.90				
23	7.87	40.0			
24	8.11				
25	8.23				
26	8.19				
27	8.16				
28	8.26				
29	8.06				
30	8.24				
31	8.18				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: January 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

30.0

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 6/5/2023

Send to DWP within 10 days after end of sampling period