

Day	pH	Alk	Phos	Other	Y/N
1	8.22				
2	8.09				
3	8.01				
4	7.99				
5	8.04				
6	7.99				
7	7.98				
8	7.91				
9	7.90				
10	7.81				
11	7.84				
12	7.89	40.0			
13	7.83				
14	7.78				
15	7.85				
16	7.90				
17	7.92				
18	7.92				
19	8.00				
20	8.04				
21	8.04				
22	8.09				
23	8.02				
24	8.16	40.0			
25	8.23				
26	8.31				
27	8.31				
28	8.26				
29	8.28				
30	8.18				
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: June 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

 (Alkalinity)

PO4

--


 (Orthophosphate)

Other

--

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 7/7/2023

Send to DWP within 10 days after end of sampling period