

Day	pH	Alk	Phos	Other	Y/N
1	8.17				
2	8.19				
3	8.04				
4	7.91				
5	8.00				
6	7.90				
7	7.89				
8	7.97				
9	8.05				
10	7.94				
11	7.97	40.0			
12	7.96				
13	8.02				
14	8.02				
15	7.97				
16	7.89				
17	7.70				
18	7.82				
19	7.74				
20	7.84				
21	7.84				
22	7.84				
23	7.75	40.0			
24	7.81				
25	7.77				
26	7.84				
27	7.89				
28	7.89				
29	8.00				
30	7.94				
31	8.19				
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: July 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 8/9/2023

Send to DWP within 10 days after end of sampling period