

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.31				
2	8.02				
3	8.01				
4	7.79	40.0			
5	7.75				
6	7.81				
7	7.84				
8	7.85				
9	7.90				
10	7.92				
11	7.88				
12	7.95				
13	7.95				
14	7.83				
15	7.73				
16	7.68	40.0			
17	7.64				
18	7.71				
19	7.74				
20	7.75				
21	7.69				
22	7.67				
23	7.87				
24	7.77				
25	7.76				
26	7.77				
27	7.77				
28	7.64	40.0			
29	7.64				
30	7.57				
31	7.69				

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

**System Name:** Wickiup Water District

**Entry Point:** B

**Sample Period:** August 2023  
*Month/Year*

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 ( )

**Print Name:** Dan Waterbury

**Signature:**

**Date:** 9/7/2023

Send to DWP within 10 days after end of sampling period