

Day	pH	Alk	Phos	Other	Y/N
1	7.67				
2	7.53				
3	7.53				
4	7.60				
5	7.65				
6	7.68				
7	7.71				
8	7.74				
9	7.80				
10	7.75	40.0			
11	7.93				
12	7.98				
13	8.03				
14	8.02				
15	8.10				
16	8.15				
17	8.09				
18	8.13				
19	8.24				
20	8.18				
21	8.25				
22	8.24	40.0			
23	8.28				
24	8.32				
25	8.29				
26	8.24				
27	8.39				
28	8.33				
29	8.07				
30	8.00				
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: September 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

 (Alkalinity)

PO4 

--


 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Dan Waterbury

Signature: 

Date: 10/9/2023

Send to DWP within 10 days after end of sampling period