

Day	pH	Alk	Phos	Other	Y/N
1	7.94				
2	8.29	40.0			
3	8.37				
4	8.46				
5	8.42				
6	8.45				
7	8.38				
8	8.39				
9	8.39				
10	8.39				
11	8.46				
12	8.55				
13	8.44				
14	8.47	40.0			
15	8.54				
16	8.52				
17	8.56				
18	8.60				
19	8.39				
20	8.48				
21	8.48				
22	8.51				
23	8.52				
24	8.58				
25	8.53				
26	8.55	40.0			
27	8.67				
28	8.63				
29	8.68				
30	8.61				
31	8.54				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: October 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 11/06/2023

Send to DWP within 10 days after end of sampling period