

Day	pH	Alk	Phos	Other	Y/N
1	7.95	40.0			
2	7.71				
3	7.75				
4	7.77				
5	7.83				
6	8.07				
7	8.25				
8	8.32				
9	8.29				
10	8.34				
11	8.34				
12	8.14	40.0			
13	8.11				
14	8.02				
15	7.97				
16	8.11				
17	7.99				
18	8.04				
19	8.11				
20	7.93				
21	7.91				
22	7.91				
23	7.86				
24	7.93	40.0			
25	7.92				
26	7.88				
27	7.89				
28	7.92				
29	7.94				
30	7.96				
31	7.98				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: December 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 1/8/2024

Send to DWP within 10 days after end of sampling period