

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.10				Y
2	8.02				Y
3	8.04				Y
4	7.97				Y
5	8.02	40.0			Y
6	8.01				Y
7	7.95				Y
8	7.91				Y
9	7.92				Y
10	7.92				Y
11	7.91				Y
12	7.96				Y
13	8.01				Y
14	8.13				Y
15	8.11				Y
16	8.01				Y
17	7.66	40.0			Y
18	7.38				Y
19	7.40				Y
20	7.37				Y
21	8.04				Y
22	7.97				Y
23	8.35				Y
24	8.40				Y
25	8.15				Y
26	8.19				Y
27	8.21				Y
28	8.22				Y
29	8.08	40.0			Y
30	8.02				Y
31	7.93				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: January 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Dan Waterbury

Signature:

Date: 2/07/2024

Send to DWP within 10 days after end of sampling period