

Day	pH	Alk	Phos	Other	Y/N
1	7.91				Y
2	7.79				Y
3	7.81				Y
4	7.84				Y
5	7.87				Y
6	7.91				Y
7	8.03				Y
8	7.99				Y
9	7.95				Y
10	7.97	40.0			Y
11	7.99				Y
12	8.05				Y
13	8.11				Y
14	8.22				Y
15	8.30				Y
16	8.34				Y
17	8.36				Y
18	8.24				Y
19	8.25				Y
20	8.32				Y
21	8.43				Y
22	8.51	40.0			Y
23	8.53				Y
24	8.48				Y
25	8.39				Y
26	8.65				Y
27	8.72				Y
28	8.63				Y
29	8.71				Y
30					Y
31					Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 3/08/2024

Send to DWP within 10 days after end of sampling period