

Day	pH	Alk	Phos	Other	Y/N
1	8.59				
2	8.47				
3	8.45				
4	8.51				
5	8.42				
6	8.47				
7	8.29	40.0			
8	8.27				
9	8.23				
10	7.91				
11	8.13				
12	8.19				
13	8.13				
14	8.07				
15	8.07				
16	8.16				
17	8.20				
18	8.15				
19	7.93	40.0			
20	8.02				
21	8.06				
22	8.07				
23	8.02				
24	7.83				
25	7.85				
26	7.78				
27	7.71				
28	7.89				
29	8.00				
30	7.96				
31	8.06	40.0			
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: March 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 4/4/2024

Send to DWP within 10 days after end of sampling period