

Day	pH	Alk	Phos	Other	Y/N
1	8.03				
2	8.03				
3	8.02				
4	8.10				
5	7.89				
6	7.92				
7	8.04				
8	7.92				
9	7.78				
10	7.89	40.0			
11	7.93				
12	7.83				
13	8.02				
14	7.99				
15	8.03				
16	8.03				
17	8.03				
18	8.04				
19	8.01				
20	8.02				
21	8.10				
22	8.03	40.0			
23	8.05				
24	7.99				
25	8.41				
26	7.99				
27	7.95				
28	7.94				
29	7.93				
30	8.02				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: April 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 5/8/2024

Send to DWP within 10 days after end of sampling period