

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1	8.10	 			
2	8.06				
3	8.07				
4	7.97	40.0			
5	8.03				
6	7.87				
7	7.87				
8	8.05				
9	8.13				
10	8.19				
11	8.28				
12	8.27		_		
13	8.34	<u> </u>			
14	8.21				
15	8.27				
16	8.22	40.0			
17	8.25				
18	8.17				
19	8.09				
20	7.98				
21	7.90				
22	7.90				
23	8.00				
24	8.04				
25	7.93				
26	8.04				
27	8.05				
28	8.09	40.0			
29	8.05				
30	8.07	1 "			
31	8.09				
	N = Ex	cursior	i) Tot	al N's	0

< <have minimums<="" th=""><th colspan="3"></th></have>					
been met for this day?	PWS ID: 41 0 0 0 6 3				
System Name: Wickiup Water District					
Entry Point: <u>B</u>					
Sample Period: May 2024					
	Month/Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by				
рΗ	7.2			
Alk	30.0	(Alkalinity)		
PO4		(Orthophosphate)		
Other		()		

Print N	lame: <u>¡Da</u>	n Waterbury
Signat	ture: /20	Mary Comments
	6/3/2024	

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350Phone (971) 673-0405 Website: http://healthoregon.org/dwp/