

Day	pH	Alk	Phos	Other	Y/N
1	7.99				
2	8.01				
3	7.93				
4	7.96				
5	8.03				
6	8.06				
7	8.04				
8	7.97				
9	7.95	40.0			
10	8.01				
11	7.96				
12	8.04				
13	7.92				
14	7.91				
15	7.90				
16	7.93				
17	7.98				
18	7.96				
19	8.01				
20	8.05				
21	7.97	40.0			
22	7.91				
23	8.01				
24	7.93				
25	7.84				
26	7.81				
27	7.81				
28	7.87				
29	7.83				
30	7.77				
31					
(No = N = Excursion) Total N's					0

ENTRY POINT

<<Have minimums been met for this day? PWS ID: 41 00063

System Name: Wickiup Water District

Entry Point: B

Sample Period: June 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 30.0 *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: (Dan Waterbury

Signature:

Date: 7/9/2024

Send to DWP within 10 days after end of sampling period