

Day	pH	Alk	Phos	Other	Y/N
1	7.78				
2	7.74				
3	7.83	40.0			
4	7.77				
5	7.81				
6	7.79				
7	7.72				
8	7.72				
9	7.76				
10	7.40				
11	7.70				
12	7.64				
13	7.79				
14	7.79				
15	7.82	40.0			
16	7.81				
17	7.86				
18	7.89				
19	7.93				
20	7.94				
21	7.95				
22	7.90				
23	7.91				
24	7.93				
25	7.88				
26	7.93				
27	7.96	40.0			
28	8.00				
29	8.56				
30	7.75				
31	7.89				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: July 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 8/8/2024

Send to DWP within 10 days after end of sampling period