

Day	pH	Alk	Phos	Other	Y/N
1	7.90				
2	7.91				
3	7.90				
4	7.95				
5	7.92				
6	7.95				
7	7.95				
8	7.92	40.0			
9	7.95				
10	7.85				
11	7.74				
12	7.98				
13	7.94				
14	7.96				
15	7.96				
16	8.07				
17	8.04				
18	7.99				
19	8.03				
20	7.97	40.0			
21	7.95				
22	7.94				
23	7.85				
24	7.74				
25	7.85				
26	7.94				
27	7.94				
28	8.10				
29	7.96				
30	7.87				
31	8.04				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: August 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 9/9/2024

Send to DWP within 10 days after end of sampling period