

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.83	40.0			
2	7.82				
3	7.86				
4	7.87				
5	7.84				
6	7.84				
7	7.65				
8	7.79				
9	7.86				
10	7.81				
11	8.04				
12	7.78				
13	7.75	40.0			
14	7.59				
15	7.73				
16	7.74				
17	7.87				
18	7.97				
19	7.99				
20	8.06				
21	7.79				
22	8.11				
23	8.14				
24	7.82				
25	7.94	40.0			
26	7.97				
27	8.10				
28	8.09				
29	8.01				
30	8.02				
31					
(No = N = Excursion) Total N's					0

<<Have

minimums  
been met for  
this day?

## ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: September 2024

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2

Alk 30.0

(Alkalinity)

PO4

(Orthophosphate)

Other

( )

Print Name: Dan Waterbury

Signature: 

Date: 10/10/2024

Send to DWP within 10 days after end of sampling period