

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.94				
2	7.96				
3	7.98				
4	7.95				
5	7.99				
6	7.95				
7	8.06				
8	8.07				
9	8.09				
10	8.11				
11	8.08				
12	8.10				
13	8.05				
14	8.09				
15	8.10				
16	8.05				
17	8.03				
18	8.04	50			
19	7.98				
20	8.01				
21	7.92				
22	7.95				
23	7.96				
24	8.09	45			
25	8.05				
26	8.05				
27	8.02				
28	8.09				
29	8.12				
30	8.05				
31	8.17	45			
(No = N = Excursion) Total N's					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: October 2024

Month/Year



Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>30.0</u>	(Alkalinity)
PO4	<u></u>	(Orthophosphate)
Other	<u></u>	(_____)

Print Name: Eric Bufkin

Signature: _____

Date: 11-08-24

Eric Bufkin

Send to DWP within 10 days after end of sampling period