

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.60				Y
2	7.64				Y
3	7.45				Y
4	7.69				Y
5	7.76				Y
6	7.66				Y
7	7.76				Y
8	7.86				Y
9	8.03				Y
10	8.08	40			Y
11	7.88				Y
12	7.93				Y
13	7.89				Y
14	7.96				Y
15	7.89				Y
16	7.40				Y
17	7.36				Y
18	7.08				Y
19	7.81				Y
20	7.78				Y
21	7.15	40			Y
22	7.38				Y
23	7.42				Y
24	7.63				Y
25	7.73				Y
26	7.45				Y
27	7.48				Y
28	8.11				Y
29	8.44				Y
30	8.25				Y
31					
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: November / 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.2</td></tr></table>	7.2	
7.2			
Alk	<table border="1"><tr><td>30.0</td></tr></table>	30.0	(Alkalinity)
30.0			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		(_____)

Print Name: Eric Bufkin

Signature: 

Date: 12/09/2025

Send to DWP within 10 days after end of sampling period