



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.62				Y
2	7.62				Y
3	7.62				Y
4	7.61				Y
5	7.66				Y
6	7.67				Y
7	7.69				Y
8	7.64				Y
9	7.52				Y
10	7.39				Y
11	7.32				Y
12	7.28				Y
13	7.46				Y
14	7.57				Y
15	7.62				Y
16	7.71				Y
17	7.78				Y
18	7.77				Y
19	7.7				Y
20	7.62				Y
21	7.56				Y
22	7.55				Y
23	7.54				Y
24	7.55				Y
25	7.57				Y
26	7.61				Y
27	7.67				Y
28	7.72				Y
29	7.73				Y
30	7.73				Y
31	7.71				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41**       7 4

**System Name:**    Bandon, City of \_\_\_\_\_

**Entry Point:**    A \_\_\_\_\_

**Sample Period:**    \_\_\_\_\_ Jan-21  
Month / Year

**Number of excursions\* during this month:**    0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**    0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

For OHA

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.1"/>	
ALK	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	( _____ )

**Print Name:** James Youravish

**Signature:**

**Date:** 7-1-2021

Send to DWP with 10 days after end of sampling period