

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.68				Y
2	7.65				Y
3	7.62				Y
4	7.62				Y
5	7.60				Y
6	7.57				Y
7	7.51				Y
8	7.47				Y
9	7.46				Y
10	7.45				Y
11	7.45				Y
12	7.47				Y
13	7.48				Y
14	7.52				Y
15	7.54				Y
16	7.58				Y
17	7.60				Y
18	7.60				Y
19	7.60				Y
20	7.57				Y
21	7.57				Y
22	7.56				Y
23	7.55				Y
24	7.54				Y
25	7.52				Y
26	7.52				Y
27	7.52				Y
28	7.54				Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **0 0 0 7 4**

System Name: Bandon, City Of

Entry Point: A

Sample Period: Feb /21
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by


pH **7.1**

ALK (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: James Youravish

Signature: 

Date: 3-1-2021

Send to DWP with 10 days after end of sampling period