

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.56				Y
2	7.58				Y
3	7.60				Y
4	7.62				Y
5	7.66				Y
6	7.70				Y
7	7.71				Y
8	7.71				Y
9	7.73				Y
10	7.76				Y
11	7.69				Y
12	7.67				Y
13	7.64				Y
14	7.61				Y
15	7.60				Y
16	7.59				Y
17	7.59				Y
18	7.59				Y
19	7.59				Y
20	7.58				Y
21	7.57				Y
22	7.55				Y
23	7.53				Y
24	7.52				Y
25	7.51				Y
26	7.52				Y
27	7.51				Y
28	7.47				Y
29	7.43				Y
30	7.41				Y
31	7.38				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: MARCH / 2021
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH 7.1
 ALK (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: James Youravish

Signature: 

Date: 4-1-2021

Send to DWP with 10 days after end of sampling period