

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.66 #				Y
2	7.65 #				Y
3	7.58 #				Y
4	7.48 #				Y
5	7.41 #				Y
6	7.41 #				Y
7	7.47 #				Y
8	7.51 #				Y
9	7.51 #				Y
10	7.49 #				Y
11	7.38 #				Y
12	7.32 #				Y
13	7.35 #				Y
14	7.41 #				Y
15	7.45 #				Y
16	7.52 #				Y
17	7.52 #				Y
18	7.50 #				Y
19	7.83 #				Y
20	7.94 #				Y
21	7.93 #				Y
22	7.89 #				Y
23	7.82 #				Y
24	7.74 #				Y
25	7.62 #				Y
26	7.57 #				Y
27	7.49 #				Y
28	7.48 #				Y
29	7.45 #				Y
30	7.42 #				Y
31	7.43 #				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41**

0	0	0	7	4
---	---	---	---	---

**System Name:**      Bandon, City of

**Entry Point:**      A

**Sample Period:**      5/21  
Month / Year

**Number of excursions\* during this month:**      0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:**      0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

**Minimum Water Quality Parameters as set by**

pH	<table border="1" style="display: inline-table;"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		(Alkalinity)
PO4	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		(Orthophosphate)
Other	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		( )

**Print Name:** James Youravish

**Signature:** 

**Date:** 6-4-21

Send to DWP with 10 days after end of sampling period