

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.70	#			Y
2	7.75	#			Y
3	7.78	#			Y
4	7.81	#			Y
5	7.83	#			Y
6	7.83	#			Y
7	7.84	#			Y
8	7.85	#			Y
9	7.84	#			Y
10	7.82	#			Y
11	7.79	#			Y
12	7.76	#			Y
13	7.77	#			Y
14	7.78	#			Y
15	7.77	#			Y
16	7.76	#			Y
17	7.72	#			Y
18	7.70	#			Y
19	7.70	#			Y
20	7.67	#			Y
21	7.68	#			Y
22	7.76	#			Y
23	7.83	#			Y
24	7.91	#			Y
25	7.96	#			Y
26	7.99	#			Y
27	8.01	#			Y
28	7.98	#			Y
29	7.69	#			Y
30	7.51	#			Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	7	4
---	---	---	---	---

System Name: Bandon, City of

Entry Point: A

Sample Period: sept / 2021
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1"><tr><td></td></tr></table>		(Alkalinity)
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		(_____)

Print Name: James Youravish

Signature: 

Date: 10-1-2021

Send to DWP with 10 days after end of sampling period