

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.49	#			Y
2	7.49	#			Y
3	7.46	#			Y
4	7.42	#			Y
5	7.38	#			Y
6	7.38	#			Y
7	7.45	#			Y
8	7.53	#			Y
9	7.58	#			Y
10	7.62	#			Y
11	7.67	#			Y
12	7.70	#			Y
13	7.73	#			Y
14	7.80	#			Y
15	7.81	#			Y
16	7.73	#			Y
17	7.64	#			Y
18	7.59	#			Y
19	7.51	#			Y
20	7.45	#			Y
21	7.41	#			Y
22	7.41	#			Y
23	7.41	#			Y
24	7.40	#			Y
25	7.39	#			Y
26	7.41	#			Y
27	7.46	#			Y
28	7.50	#			Y
29	7.63	#			Y
30	7.72	#			Y
31	7.73	#			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: OCT / 2021
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH	7.1	
ALK		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: James Youravish

Signature:

Date: 11-2-21

Send to DWP with 10 days after end of sampling period