

### Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.41	#			Y
2	7.48	#			Y
3	7.57	#			Y
4	7.66	#			Y
5	7.76	#			Y
6	7.90	#			Y
7	8.03	#			Y
8	8.06	#			Y
9	8.03	#			Y
10	7.97	#			Y
11	7.90	#			Y
12	7.85	#			Y
13	7.84	#			Y
14	7.86	#			Y
15	7.87	#			Y
16	7.84	#			Y
17	7.77	#			Y
18	7.71	#			Y
19	7.67	#			Y
20	7.65	#			Y
21	7.66	#			Y
22	7.67	#			Y
23	7.65	#			Y
24	7.63	#			Y
25	7.64	#			Y
26	7.70	#			Y
27	7.74	#			Y
28	7.76	#			Y
29	7.78	#			Y
30	7.79	#			Y
31	7.79	#			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41**

0	0	0	7	4
---	---	---	---	---

**System Name:**      Bandon, City of

**Entry Point:**      A

**Sample Period:**      JANUARY / 2022  
Month / Year

**Number of excursions\* during this month:**      0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:**      0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

**Minimum Water Quality Parameters as set by**

pH	<table border="1"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1"><tr><td></td></tr></table>		(Alkalinity)
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		( )

**Print Name:** James Youravish

**Signature:**

**Date:** 2/1/2022

Send to DWP with 10 days after end of sampling period