



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	p	Alk	Phos	Other	Y/N
1	7.77				Y
2	7.76				Y
3	7.78				Y
4	7.78				Y
5	7.79				Y
6	7.80				Y
7	7.81				Y
8	7.80				Y
9	7.79				Y
10	7.78				Y
11	7.75				Y
12	7.69				Y
13	7.66				Y
14	7.66				Y
15	7.65				Y
16	7.66				Y
17	7.70				Y
18	7.73				Y
19	7.78				Y
20	7.81				Y
21	7.82				Y
22	7.81				Y
23	7.71				Y
24	7.74				Y
25	7.73				Y
26	7.75				Y
27	7.75				Y
28	7.72				Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41**

0	0	0	7	4
---	---	---	---	---

**System Name:**      Bandon, City of

**Entry Point:**      A

**Sample Period:**      FEB/2022  
Month / Year

**Number of excursions\* during this month:** \_\_\_\_\_ 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_ 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

For OHA

**Minimum Water Quality Parameters as set by**

pH	<table border="1"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1"><tr><td> </td></tr></table>		(Alkalinity)
PO4	<table border="1"><tr><td> </td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td> </td></tr></table>		( _____ )

**Print Name:** James Youravish

**Signature:**

**Date:** 3-1-2022

Send to DWP with 10 days after end of sampling period