

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.68	#			Y
2	7.63	#			Y
3	7.54	#			Y
4	7.44	#			Y
5	7.37	#			Y
6	7.33	#			Y
7	7.35	#			Y
8	7.45	#			Y
9	7.65	#			Y
10	7.73	#			Y
11	7.84	#			Y
12	7.92	#			Y
13	7.90	#			Y
14	7.85	#			Y
15	7.77	#			Y
16	7.67	#			Y
17	7.54	#			Y
18	7.46	#			Y
19	7.43	#			Y
20	7.44	#			Y
21	7.48	#			Y
22	7.53	#			Y
23	7.58	#			Y
24	7.62	#			Y
25	7.61	#			Y
26	7.59	#			Y
27	7.55	#			Y
28	7.47	#			Y
29	7.39	#			Y
30	7.36	#			Y
31	7.37	#			Y

(No = N = Excursion) Total N's

0

<<Have minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: March / 2022

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are

For OHA

Minimum Water Quality

Parameters as set by

pH

7.1

ALK

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: James Youravish

Signature: [Signature]

Date: 4-5-2022

Send to DWP with 10 days after end of
sampling period