

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.95	#			Y
2	7.96	#			Y
3	8.01	#			Y
4	8.07	#			Y
5	8.07	#			Y
6	8.09	#			Y
7	8.10	#			Y
8	8.03	#			Y
9	8.09	#			Y
10	8.04	#			Y
11	8.04	#			Y
12	7.95	#			Y
13	7.92	#			Y
14	7.91	#			Y
15	7.87	#			Y
16	7.69	#			Y
17	7.61	#			Y
18	7.63	#			Y
19	7.64	#			Y
20	7.69	#			Y
21	7.77	#			Y
22	7.82	#			Y
23	7.94	#			Y
24	7.98	#			Y
25	8.08	#			Y
26	8.05	#			Y
27	8.11	#			Y
28	8.03	#			Y
29	8.11	#			Y
30	8.11	#			Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	7	4
---	---	---	---	---

System Name: Bandon, City of

Entry Point: A

Sample Period: JUNE / 2022
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1"><tr><td></td></tr></table>		(Alkalinity)
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		(_____)

Print Name: James Youravish

Signature: 

Date: 7-5-22

Send to DWP with 10 days after end of sampling period