



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.05	#			Y
2	7.97	#			Y
3	7.90	#			Y
4	7.82	#			Y
5	7.85	#			Y
6	7.94	#			Y
7	7.95	#			Y
8	7.87	#			Y
9	7.77	#			Y
10	7.80	#			Y
11	7.87	#			Y
12	7.86	#			Y
13	7.92	#			Y
14	7.95	#			Y
15	7.92	#			Y
16	7.88	#			Y
17	7.89	#			Y
18	7.90	#			Y
19	7.86	#			Y
20	7.81	#			Y
21	7.83	#			Y
22	7.86	#			Y
23	7.75	#			Y
24	7.73	#			Y
25	7.71	#			Y
26	7.71	#			Y
27	7.74	#			Y
28	7.74	#			Y
29	7.71	#			Y
30	7.69	#			Y
31	7.71	#			Y

(No = N = Excursion) Total N's

0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: July / 2002
Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH 7.1
 ALK (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: James Youravish

Signature:

Date: 8-4-02

Send to DWP with 10 days after end of sampling period