



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.59				Y
2	7.67				Y
3	7.75				Y
4	7.81				Y
5	7.83				Y
6	7.84				Y
7	7.88				Y
8	7.90				Y
9	7.88				Y
10	7.85				Y
11	7.81				Y
12	7.80				Y
13	7.79				Y
14	7.77				Y
15	7.76				Y
16	7.77				Y
17	7.75				Y
18	7.70				Y
19	7.70				Y
20	7.65				Y
21	7.60				Y
22	7.56				Y
23	7.51				Y
24	7.47				Y
25	7.41				Y
26	7.36				Y
27	7.36				Y
28	7.36				Y
29					Y
30					Y
31					Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Bandon, City of

Entry Point: A

Sample Period: February 2023
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH (Alkalinity)
 ALK (Orthophosphate)
 PO4
 Other

Print Name: James Youravish

Signature:

Date: 3-3-2023

Send to DWP with 10 days after end of sampling period