

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|--------------------------------|------|-----|------|-------|-----|
| 1 | 7.35 | | | | Y |
| 2 | 7.33 | | | | Y |
| 3 | 7.32 | | | | Y |
| 4 | 7.31 | | | | Y |
| 5 | 7.30 | | | | Y |
| 6 | 7.30 | | | | Y |
| 7 | 7.29 | | | | Y |
| 8 | 7.28 | | | | Y |
| 9 | 7.31 | | | | Y |
| 10 | 7.32 | | | | Y |
| 11 | 7.39 | | | | Y |
| 12 | 7.44 | | | | Y |
| 13 | 7.51 | | | | Y |
| 14 | 7.56 | | | | Y |
| 15 | 7.54 | | | | Y |
| 16 | 7.49 | | | | Y |
| 17 | 7.42 | | | | Y |
| 18 | 7.36 | | | | Y |
| 19 | 7.35 | | | | Y |
| 20 | 7.37 | | | | Y |
| 21 | 7.38 | | | | Y |
| 22 | 7.34 | | | | Y |
| 23 | 7.38 | | | | Y |
| 24 | 7.41 | | | | Y |
| 25 | 7.39 | | | | Y |
| 26 | 7.35 | | | | Y |
| 27 | 7.38 | | | | Y |
| 28 | 7.50 | | | | Y |
| 29 | 7.59 | | | | Y |
| 30 | 7.61 | | | | Y |
| 31 | 7.55 | | | | Y |
| (No = N = Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: March 2023

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

| | | |
|-------|-----|------------------|
| pH | 7.1 | |
| ALK | | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Other | | (_____) |

Print Name: James Youravish

Signature:

Date: 4-4-2023

Send to DWP with 10 days after end of sampling period