

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.57				Y
2	7.56				Y
3	7.52				Y
4	7.45				Y
5	7.47				Y
6	7.49				Y
7	7.48				Y
8	7.45				Y
9	7.41				Y
10	7.38				Y
11	7.37				Y
12	7.27				Y
13	7.22				Y
14	7.26				Y
15	7.35				Y
16	7.44				Y
17	7.58				Y
18	7.64				Y
19	7.63				Y
20	7.58				Y
21	7.60				Y
22	7.61				Y
23	7.59				Y
24	7.50				Y
25	7.43				Y
26	7.36				Y
27	7.34				Y
28	7.36				Y
29	7.38				Y
30	7.39				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41   

System Name: Bandon, City of

Entry Point: A

Sample Period: APRIL / 2023  
Month / Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.1"/>	
ALK	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	( )

Print Name: James Youravish

Signature: 

Date: 5-2-23

Send to DWP with 10 days after end of sampling period