

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.65				Y
2	7.63				Y
3	7.62				Y
4	7.62				Y
5	7.63				Y
6	7.66				Y
7	7.69				Y
8	7.72				Y
9	7.77				Y
10	7.77				Y
11	7.70				Y
12	7.66				Y
13	7.63				Y
14	7.62				Y
15	7.61				Y
16	7.57				Y
17	7.58				Y
18	7.61				Y
19	7.64				Y
20	7.67				Y
21	7.67				Y
22	7.61				Y
23	7.61				Y
24	7.65				Y
25	7.68				Y
26	7.65				Y
27	7.62				Y
28	7.63				Y
29	7.63				Y
30	7.61				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	7	4
---	---	---	---	---

System Name: Bandon, City of

Entry Point: A

Sample Period: 6/2023
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.1</td></tr></table>	7.1	
7.1			
ALK	<table border="1"><tr><td></td></tr></table>		(Alkalinity)
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		()

Print Name: James Youravish

Signature: 

Date: 7-9-2023

Send to DWP with 10 days after end of sampling period