



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	7.64				Y
3	7.68				Y
4	7.68				Y
5	7.66				Y
6	7.64				Y
7	7.62				Y
8	7.64				Y
9	7.64				Y
10	7.57				Y
11	7.51				Y
12	7.49				Y
13	7.49				Y
14	7.53				Y
15	7.54				Y
16	7.54				Y
17	7.52				Y
18	7.51				Y
19	7.51				Y
20	7.46				Y
21	7.46				Y
22	7.54				Y
23	7.58				Y
24	7.57				Y
25	7.62				Y
26	7.65				Y
27	7.62				Y
28	7.57				Y
29	7.54				Y
30	7.50				Y
31	7.52				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: July/2023
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH 7.1

ALK (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: James Youravish

Signature:

Date: 8-1-2023

Send to DWP with 10 days after end of sampling period