



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.76				Y
2	7.71				Y
3	7.67				Y
4	7.66				Y
5	7.62				Y
6	7.60				Y
7	7.62				Y
8	7.64				Y
9	7.65				Y
10	7.66				Y
11	7.66				Y
12	7.64				Y
13	7.62				Y
14	7.63				Y
15	7.66				Y
16	7.69				Y
17	7.64				Y
18	7.55				Y
19	7.53				Y
20	7.57				Y
21	7.62				Y
22	7.66				Y
23	7.64				Y
24	7.61				Y
25	7.61				Y
26	7.66				Y
27	7.71				Y
28	7.78				Y
29	7.84				Y
30	7.88				Y
31	7.91				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41**      0 0 0 7 4

**System Name:**    Bandon, City of

**Entry Point:**     A

**Sample Period:**         OCT    2023  
Month / Year

**Number of excursions\* during this month:**          0      
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**          0      
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

*For OHA*

**Minimum Water Quality Parameters as set by**

pH      7.1  
 ALK        (Alkalinity)  
 PO4       (Orthophosphate)  
 Other      ( )

**Print Name:** James Youravish

**Signature:** 

**Date:** 11-2-23

Send to DWP with 10 days after end of sampling period