

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.82				Y
2	7.78				Y
3	7.75				Y
4	7.74				Y
5	7.72				Y
6	7.67				Y
7	7.64				Y
8	7.61				Y
9	7.57				Y
10	7.56				Y
11	7.54				Y
12	7.50				Y
13	7.50				Y
14	7.49				Y
15	7.49				Y
16	7.46				Y
17	7.41				Y
18	7.38				Y
19	7.36				Y
20	7.38				Y
21	7.41				Y
22	7.43				Y
23	7.44				Y
24	7.42				Y
25	7.40				Y
26	7.39				Y
27	7.40				Y
28	7.41				Y
29	7.43				Y
30	7.43				Y
31	7.41				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Bandon, City of

Entry Point: A

Sample Period: JANUARY 2024
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH (Alkalinity)
 ALK (Orthophosphate)
 PO4
 Other

Print Name: James Youravish

Signature: 

Date: 1-1-24

Send to DWP with 10 days after end of sampling period