



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.53				Y
2	7.57				Y
3	7.59				Y
4	7.58				Y
5	7.57				Y
6	7.55				Y
7	7.55				Y
8	7.54				Y
9	7.54				Y
10	7.57				Y
11	7.61				Y
12	7.62				Y
13	7.62				Y
14	7.60				Y
15	7.57				Y
16	7.54				Y
17	7.51				Y
18	7.49				Y
19	7.47				Y
20	7.47				Y
21	7.49				Y
22	7.50				Y
23	7.53				Y
24	7.55				Y
25	7.57				Y
26	7.56				Y
27	7.54				Y
28	7.55				Y
29	7.57				Y
30	7.56				Y
31	7.55				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: March 2024  
Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

For OHA

**Minimum Water Quality Parameters as set by**

pH 7.1  
 ALK  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  ( )

Print Name: James Youravish

Signature:

Date: 4-2-2022

Send to DWP with 10 days after end of sampling period