

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.52				Y
2	7.34				Y
3	7.40				Y
4	7.39				Y
5	7.45				Y
6	7.33				Y
7	7.35				Y
8	7.76				Y
9	7.94				Y
10	7.88				Y
11	7.78				Y
12	7.77				Y
13	7.76				Y
14	7.69				Y
15	7.75				Y
16	7.79				Y
17	7.83				Y
18	7.88				Y
19	7.85				Y
20	7.76				Y
21	7.76				Y
22	7.81				Y
23	7.83				Y
24	7.88				Y
25	7.92				Y
26	7.95				Y
27	8.03				Y
28	7.95				Y
29	7.87				Y
30	7.87				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

### ENTRY POINT

**PWS ID: 41**      0 0 0 7 4

**System Name:**      Bandon, City of

**Entry Point:**      A

**Sample Period:**      June 2024  
Month / Year


**Number of excursions\* during this month:**      0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**      0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

For OHA

**Minimum Water Quality Parameters as set by**

pH      7.1  
 ALK        (Alkalinity)  
 PO4        (Orthophosphate)  
 Other        ( )

**Print Name:** James Youravish  
**Signature:**   
**Date:** 7-2-2024

Send to DWP with 10 days after end of sampling period