

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.50				Y
2	7.63				Y
3	7.77				Y
4	7.84				Y
5	7.75				Y
6	7.70				Y
7	7.63				Y
8	7.52				Y
9	7.42				Y
10	7.32				Y
11	7.31				Y
12	7.37				Y
13	7.49				Y
14	7.53				Y
15	7.59				Y
16	7.64				Y
17	7.62				Y
18	7.65				Y
19	7.63				Y
20	7.61				Y
21	7.57				Y
22	7.61				Y
23	7.53				Y
24	7.53				Y
25	7.40				Y
26	7.23				Y
27	7.27				Y
28	7.26				Y
29	7.45				Y
30	7.55				Y
31	7.52				Y
(No = N = Excursion) Total N's					0

<<Have minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: Dec 2024
Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are

For OHA

Minimum Water Quality
Parameters as set by

pH 7.1
ALK (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: James Youravish

Signature: 

Date: 11-27-2025

Send to DWP with 10 days after end of
sampling period